

Sommario

Connection examples	4
---------------------------	---



The cabling must be carried out by specialist personnel and fitted with suitable anti-static precautions. Before handling the controller, disconnect the power and all parts connected to it. To guarantee compliance with EC regulations, the power supply must have a galvanic isolation of at least 1500Vac.

Power supply	24 Vdc
Voltage range	22 - 27 Vdc
Max. absorption	@power@W

Connector

CN1		Terminal	Symbol	Description
		1	+	DC power positive
		2	GROUND	Gnd-PE (signals)
		3	—	DC power 0V

Connection examples



Use an isolated power unit with 24Vdc +/-5% output conform to EN60950-1.

	Use two separate power units: one for the control circuit and one for the power circuit
	For a single power unit, use two separate lines: one for the control and one for the power
	DO NOT use the same lines for the power circuit and the controller

Documento generato automaticamente da **Qem Wiki** - <https://wiki.qem.it/>

Il contenuto wiki è costantemente aggiornato dal team di sviluppo, è quindi possibile che la versione online contenga informazioni più recenti di questo documento.