



Table of Contents

Connectors

@cna@-CAN1 PORT @cna@-CAN2 PORT	Terminal	Symbol	Description
	1	0V	CAN common
	2	CAN L	Terminal CAN L
	3	CAN H	Terminal CAN H

Setup of CAN1 and CAN2 PORT Termination resistances

@dip@	Num. Dip	Name Dip	Setting of DIP	Function
	1	JP1	ON	CAN1 Termination
	2	JP2	ON	
	3	JP1	ON	CAN2 Termination
	4	JP2	ON	



When activating the CAN1 port termination, set dip's JP1 and JP2 to ON.
When activating the CAN2 port termination, set dip's JP1 and JP2 to ON.

Documento generato automaticamente da **Qem Wiki** - <https://wiki.qem.it/>

Il contenuto wiki è costantemente aggiornato dal team di sviluppo, è quindi possibile che la versione online contenga informazioni più recenti di questo documento.