

Sommario

THE DAC DEVICE	3
1. Introduction	3
1.1 Declaration of the device	3
1.2 Execution Description	3
1.2.1 List of Parameters	4
1.2.2 Status List	5
1.2.3 List of Commands	6
1.3 Application Example	6
1.3.1 Configuration Unit	6
1.3.2 Unit QCL	6

THE DAC DEVICE

1. Introduction

The DAC device is used to manage an analog output with +/- 10V and a 16bit resolution. Its main characteristics:

- setting in bit of the voltage to generate in output
- setting an offset to the output voltage
- setting a minimum and maximum limit to the output voltage
- inversion of the output voltage value sign

1.1 Declaration of the device

The INTDEVICE section in the configuration unit must have the declaration of the hardware resources needed to use the DAC device. At least one analog output must be present. In the INTDEVICE section of the configuration unit the following definition must be added:

```
-----  
Device definitions  
-----  
INTDEVICE  
<device name> DAC <IOutA>
```

where:

Field name	Description	Example	Notes
<device name>	Nome assegnato al device.	AnOut	
DAC	Keyword identifying the analog output device		
<IOutA>	Hardware address of the DAC component of the analog output	3.AN01	




Unlike other devices, the DAC device does not need a sampling time since it merely converts the input data and updates the output only when the data is entered.

Example

```
-----  
Devices definitions  
-----  
INTDEVICE  
AnOut DAC 2.AN01
```

1.2 Execution Description

Block chart of the device:



The DAC device, since it works with 16 bit resolution, accepts input values between -32768 and 32767. The output voltage is proportional to the value entered by the user. The device has a symmetrical behaviour around the zero analog voltage at less than any offset value entered. The minimum and maximum analog voltages can be set by the lowlim and uplim parameters, always remaining within $\pm 10V$:

- 32767 -> +10 V (maximum permitted),
- -32768 -> -10 V (minimum permitted).

The value introduced in the device to obtain an analog voltage VOUT is calculated by the proportion:

- for positive values: $in = (VOUT * 32767) / 10$,
- for negative values: $in = (VOUT * 32768) / 10$.

1.2.1 List of Parameters

1.2.1.1 in

Short description	Input DAC
Dimension	Word
Default value	Retentive
Access type	Read - Write
Unit measure	-
Valid range	-32768-32767
Parameter ID	-
Write conditions	-

Description:

Parameter that allows to select the voltage in output from the DAC, which must be between -32768 to 32767. To obtain an analog voltage, VOUT, the following parameter calculation is used:

- for positive values: $in = (VOUT * 32767) / 10$,
 - for negative values: $in = (VOUT * 32768) / 10$.
-

1.2.1.2 offset

Short description	Output offset
Dimension	Word
Default value	Retentive
Access type	Read - Write
Unit measure	-
Valid range	-32768-32767
Parameter ID	-
Write conditions	-

Description:

Offset of the analog output. This parameter defines the correction on the analog output. It is entered in whole values between -32768 and 32767 and the usual calculation is used to obtain a value in Volts.

1.2.1.3 uplim

Short description	Maximum output voltage
Dimension	Word
Default value	Retentive
Access type	Read - Write
Unit measure	-
Valid range	-32768-32767
Parameter ID	-
Write conditions	-

Description:

This parameter indicates the maximum output voltage from the device. If the value calculated by the DAC is over *uplim* this is forced to the parameter value. The value entered can be positive or negative with whole values between -32768 and 32767. To obtain a value in Volts the usual calculation is used.

1.2.1.4 lowlim

Short description	Minimum output voltage
Dimension	Word
Default value	Retentive
Access type	Read - Write
Unit measure	-
Valid range	-32768-32767
Parameter ID	-
Write conditions	-

Description:

This parameter indicates the minimum voltage output from the device. If the value calculated by the DAC exceeds *lowlim* this is forced to the parameter value. The value entered can be either positive or negative with whole values between -32768 and 32767. To obtain a value in Volts the usual proportion is used.

1.2.1.5 out

Short description	Output DAC
Dimension	Word
Default value	Retentive
Access type	Read
Unit measure	-
Valid range	<i>lowlim-uplim</i>
Parameter ID	-
Write conditions	-

Description:

Parameter that expresses the voltage output of the DAC. The value viewed is the algebraic sum of parameter value settings and offset. If the value exceeds the limits set by *uplim* and *lowlim*, *out* is forced to the pre-set maximum or minimum value. This parameter is also expressed in whole values between -32768 and 32767 that are converted in Volts by the usual calculation.

1.2.2 Status List

1.2.2.1 st_lowlim

Short description	Output voltage status under minimum limit
Default value	Retentive
Status ID	-

Description

The status signals the output voltage is under the lower limit. The device has calculated a voltage value beyond the limit set by *lowlim* and the *lowlim* value has therefore been forced on the output:

- 0: output voltage in the lower limit,
 - 1: output voltage under the lower limit.
-

1.2.2.2 st_uplim

Short description	Output voltage status over maximum limit
Default value	Ritentivo
Status ID	-

Description

The status signals the output voltage is over the maximum limit. The device has calculated a voltage value beyond the limit set by *uplim* and the *uplim* value has therefore been forced on the output:

- 0: output voltage in upper limit,
 - 1: output voltage over the upper limit.
-

1.2.2.3 st_outrev

Short description	Inversion status of output voltage value sign
Default value	Retentive
Status ID	-

Description

The status, after the OUTREV command, signals the output voltage value has changed sign.

1.2.3 List of Commands

The commands provided to manage the device are listed below: the device executes the commands in the order they are received.

1.2.3.1 OUTREV

Short description	Inversion of output voltage sign.
Condition	-
Default value	-
Command ID	-

Description

The output voltage value sign is inverted

1.2.3.2 OUTDIR

Short description	Reset output voltage sign.
Condition	-
Default value	-
Command ID	-

Description

The output voltage value sign is reset

1.3 Application Example

This section gives an abstract of code lines as an example in the first steps of using the device in question. As explained, the first step is to declare the device in the configuration unit. Then a new QCL unit can be created for writing the the code to command the controller. The code lines and comments below are examples of some simple operations executed by the device.

1.3.1 Configuration Unit

```
[...]
BÜS
1 1K31F 30
2 iMG8F :
3 .
4 .

INPUT
ifChangeOut F 3.INP01 ;Output voltage change command
INTDEVICE
AnalogOut DAC 3.AN01
```

1.3.2 Unit QCL

```

SYSTEM
    slOutAna    L IN          ;Variable for analog output
GLOBAL
    gfChange    F            ;Rise edge flag
BEGIN
    ; Initializations
    AnalogOut.offset = 0
    AnalogOut.uplim = 32767      ;Max analog output as 10V
    AnalogOut.lowlim = -32768   ;Min analog output as -10V
    AnalogOut.OUTDIR = 1         ;Set the right analog output sign
    WAIT NOT AnalogOut.st_outrev ;WAIT the right state
    slOutAna = 0                ;Set the variable as 0V
MAIN:
    IF ifChangeOut
        IF NOT gfChange;Wait for input activation
            gfChange= 1 ;Set the change made flag
            AnalogOut.in = (slOutAna * AnalogOut.uplim) /100 ;Set the device analog output
        ENDIF
    ELSE
        gfChange = 0 ;Reset the change made flag
    ENDIF
    WAIT 1
    JUMP MAIN
END

```

When the *ifChangeOut* input is activated, on the rise front, the output voltage value is updated by the declared DAC device (here named *AnalogOut*). The voltage value in tenths of a volt is contained in the *slOutAna* variable. Another unit in the project can access the *slOutAna* variable and set the required value.

Documento generato automaticamente da **Qem Wiki** - <https://wiki.qem.it/>

Il contenuto wiki è costantemente aggiornato dal team di sviluppo, è quindi possibile che la versione online contenga informazioni più recenti di questo documento.